



300 Series - Commercial Slat Door - Windload Certified

PART 1 - GENERAL

1.01 DESCRIPTION

- A. Type:** Standard Commercial Flat Slat Doors to be manufactured by Janus International Group.
- B. Operation:** to be chain hoist operated using gear reduction, motor operation optional.
- C. Mounting:** to be interior face mounted on a prepared opening.

1.02 RELATED WORK

- A. Opening preparation, access panels, finish or field painting are in the scope of the work of other sections or trades.

PART 2 - PRODUCT

2.01 CURTAIN

A. Slats: Galvanized steel cold roll formed in continuous lengths. Galvanized according to A.S.T.M. A653-G90 and finished with baked epoxy primer and baked polyester topcoat.

1. Model 324 – 24 gauge in flat or curved slat up to 16' wide x 16' high
2. Model 322 – 22 gauge in flat or curved slat up to 12' wide x 12' high

B. Endlocks: each end of alternate slats to be fitted with windlocks to provide a wearing surface in the guides and to maintain slat alignment and properly engage wind bar insert during high wind pressures. Fastened with 1/4" rivets.

C. Windload: Door construction designed to satisfy windload of +74.4/-69.8psf for sizes up to 12'0" wide by 14'0" high. Consult factory for available sizes or higher windload.

D. Bottom Bar: curtain to be reinforced with a bottom bar consisting of a 2" x 2" x 1/8" (50.8mm x 50.8mm x 4.76mm) structural steel angle with E.P.D.M. astragal.

2.02 DRUM ASSEMBLY

A. Drum: to be formed with 24 gauge galvanized steel sheet rolled around and attached to stamped 16 gauge galvanized steel drums to restrict deflection to .03" per foot (2.5mm/m) of door width.

B. Springs: to be oil tempered, grease packed helical torsion type designed to cycle 12,500 times with an overload factor of 25%. Springs are to be mounted on a 1" (25.4mm) black steel pipe of minimum Schedule 40.

C. End Bearings: to be self lubricating ball bearings.

2.03 SUPPORT BRACKETS

A. Support Brackets: to be 3/16" (4.76mm) thick steel angles and a 1/4" (6.35mm) thick steel diagonal brace welded in a triangular form to support ends of drum assembly.

2.04 OPERATION

A. Drive: reduction gear chain hoist standard for all sizes.

B. Hand Chain: to be galvanized machine link. Pull not to exceed 35 lbs.

C. Electric Operation: Wall mounted jackshaft motor.

2.05 GUIDE ASSEMBLY

A. Wall Angles: to be 1/4" minimum thickness structural steel angles.

B. Guides: to be 3/16" minimum thickness structural steel angles with 1/2" steel square bar welded to outer angle for windlock engagement to have removable headstops.

C. Guide Depth: to provide slat penetration adequate to satisfy specified windloading.

2.06 LOCKING

A. Hand Chain Lock: bracket, to be mounted on guide angle or wall.

B. Curtain Lock: hardened galvanized steel slide bolts attached to bottom angle suitable for padlocking. (padlock by others)